



Compiled Date	14/12/2021
File Number	21.22.42

LGOIMA

When releasing responses to previous LGOIMA requests, names and contact details of individual requestors will be withheld to protect their privacy.

Information requested by the media, lobby groups, public sector organisations and MPs will always be published, while information specific to an individual or their property will not generally be published.

Request from:	Private Individual
Information requested:	Fire suppression systems for water treatment plants
Response by:	Simon Bastion, Chief Executive

14 December 2021

Private Individual

Via Email:

Dear Private Individual

Official information request for information on fire suppression systems for water treatment plants

I refer to your official information request dated 13 December 2021 for information on fire suppression systems for water pump stations and treatment plants.

You have asked for the following information:

1) What fire suppression systems do you have in place for your electrical infrastructure for water pump stations and treatment plants?

Our water pump stations and treatment plants have hand held fire extinguishers only. Wastewater pond systems do not have fire extinguishers.

2) What fire suppression systems do you have in place for electrical switchboards and MCC rooms.

We have fire extinguishers.

If you have gas flood systems:

3) What gas flood system?

N/A

4) When is the vessel to be pressure tested in order to retain Building WOF?

N/A

5) Have they had any false activations? This would require refilling of the pressure vessels

N/A

6) Who is the asset manager responsible for protecting your critical infrastructure?

Any further correspondence relating to the fire systems and the water pump stations and treatment plants can be directed to the 3 Waters Engineer – martin.ross@westlanddc.govt.nz

There is no charge in supplying this information to you.

Council has adopted a Proactive Release Policy and accordingly may publish LGOIMA responses on the Council Website at <https://www.westlanddc.govt.nz/lgoima-responses>.

The collection and use of personal information by the Westland District Council is regulated by the Privacy Act 2020. Westland District Council's Privacy Statement is available on our website [here](#)

If you wish to discuss this decision with us, please feel free to contact Mary-anne Bell, Senior Administration Officer at LGOIMA@westlanddc.govt.nz, 03 756 9091.

Sincerely,

A handwritten signature in black ink, consisting of several overlapping loops and a long horizontal stroke extending to the right.

Simon Bastion | Chief Executive

SB/MB