



Compiled Date	14/10/2021
File Number	21.22.23

LGOIMA

When releasing responses to previous LGOIMA requests, names and contact details of individual requestors will be withheld to protect their privacy.

Information requested by the media, lobby groups, public sector organisations and MPs will always be published, while information specific to an individual or their property will not generally be published.

Request from:	Private Individual
Information requested:	Boil water notices
Response by:	Simon Bastion, Chief Executive

14 October 2021

Private Individual

Via Email:

Dear Private Individual

Official information request for boil water notices

I refer to your official information request dated 08 October 2021 for boil water notices for the previous year and any current boil water notices.

The information you have requested is enclosed.

There is no charge in supplying this information to you.

Council has adopted a Proactive Release Policy and accordingly may publish LGOIMA responses on the Council Website at <https://www.westlanddc.govt.nz/lgoima-responses>.

The collection and use of personal information by the Westland District Council is regulated by the Privacy Act 2020. Westland District Council's Privacy Statement is available on our website [here](#)

If you wish to discuss this decision with us, please feel free to contact Mary-anne Bell, Senior Administration Officer at LGOIMA@westlanddc.govt.nz, 03 756 9091.

Sincerely,

A handwritten signature in black ink, consisting of several overlapping loops and a long horizontal stroke extending to the right.

Simon Bastion | Chief Executive

SB/MB

Water Supply Affected	Date Of Initial Incident	Date of Resolution (i.e. when Boil Water Notice lifted)	MoH notified Y/N	Public notified & how e.g. e-txt, newspaper, website	Reason for Boil Notice	E.coli Level (if applicable)	Location	Additional comments
Kumara	12.02.2021	19.02.2021	Y	E-txt, website, FB	Unchlorinated supply. E.coli positive sample in reticulation	3	Reticulation	First follow up sample also showed positive E.coli result. The reservoir was shock dosed with chlorine. Nothing found within the reticulation.

WDC 21.22.23 Released under LGOIMA

Water Supply Affected	Date Of Initial Incident	Date of Resolution (i.e. when Boil Water Notice lifted)	MoH notified Y/N	Public notified & how e.g. e-txt, newspaper, website	Reason for Boil Notice	E.coli Level (if applicable)	Location	Additional comments
Fox Glacier	10.01.2020	14.01.2020	Y	E-txt, website, FB	E.coli	1	Reticulation	Advised to take FAC samples from the retic by DWA. Investigated by Westroads. Possibly a contaminated sample taken in the retic.
Fox Glacier	17.01.2020	22.01.2020	Y	n/a	E.coli	2	After Plant	Advised to take FAC samples from the retic by DWA. Investigated by Westroads and nothing obvious identified as possible cause. Considered that a 'Boil Water' notice was not required.
Fox Glacier	29.01.2020	12.02.2020	Y	E-txt, website, FB	E.coli	34	After Plant	Advised to take FAC samples from the retic by DWA. Investigated by Westroads. Chlorine dose rate increased, media filters manually backwashed, intake and stream checked and retic flushing.
Fox Glacier	4.03.2020	10.03.2020	Y	E-txt, website, FB	E.coli	>200	After Plant	Advised to take FAC samples from the retic by DWA. Investigated by Westroads. Chlorine dose rate increased, media filters manually backwashed, intake and stream checked and retic flushing. Shock dosing of raw water tank.

WDC 21.22.23 Released under LGOMA